



**CSA  
Group**

**ASME A112.4.14-2017/  
CSA B125.14-17**

# **Manually operated valves for use in plumbing systems**



# ***Legal Notice for Harmonized Standard Jointly Developed by ASME and CSA Group***

## **Intellectual property rights and ownership**

As between American Society of Mechanical Engineers (“ASME”) and Canadian Standards Association (Operating as “CSA Group”) (collectively “ASME and CSA Group”) and the users of this document (whether it be in printed or electronic form), ASME and CSA Group are the joint owners of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. The unauthorized use, modification, copying, or disclosure of this document may violate laws that protect the intellectual property of ASME and CSA Group and may give rise to a right in ASME and CSA Group to seek legal redress for such use, modification, copying, or disclosure. ASME and CSA Group reserve all intellectual property rights in this document.

## **Disclaimer and exclusion of liability**

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document’s fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party’s intellectual property rights. ASME and CSA Group do not warrant the accuracy, completeness, or currency of any of the information published in this document. ASME and CSA Group make no representations or warranties regarding this document’s compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL ASME AND CSA GROUP, THEIR RESPECTIVE VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF ASME OR CSA GROUP HAVE BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, ASME and CSA Group are not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and ASME and CSA Group accept no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

ASME and CSA Group have no power, nor do they undertake, to enforce compliance with the contents of the standards or other documents they jointly publish.

## **Authorized use of this document**

This document is being provided by ASME and CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF format.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by ASME and CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way or remove this Legal Notice from the attached standard;
- sell this document without authorization from ASME and CSA Group ; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



# ***Standards Update Service***

## ***ASME A112.4.14-2017/CSA B125.14-17 June 2017***

**Title:** *Manually operated valves for use in plumbing systems*

To register for e-mail notification about any updates to this publication

- go to [shop.csa.ca](http://shop.csa.ca)
- click on **CSA Update Service**

The **List ID** that you will need to register for updates to this publication is **2425143**.

If you require assistance, please e-mail [techsupport@csagroup.org](mailto:techsupport@csagroup.org) or call 416-747-2233.

Visit CSA Group's policy on privacy at [www.csagroup.org/legal](http://www.csagroup.org/legal) to find out how we protect your personal information.

# ***ASME/CSA Standard***

## ***ASME A112.4.14-2017/CSA B45.14-17 Manually operated valves for use in plumbing systems***



*®A trademark of the Canadian Standards Association and CSA America Inc., operating as "CSA Group"*

*Published in June 2017 by CSA Group  
A not-for-profit private sector organization  
178 Rexdale Boulevard, Toronto, Ontario, Canada M9W 1R3  
1-800-463-6727 • 416-747-4044*

***Visit the CSA Group Online Store at [shop.csa.ca](http://shop.csa.ca)***

*The American Society of Mechanical Engineers (ASME)  
Two Park Avenue  
New York, NY 10016-5990, USA  
1-800-843-2763*

***Visit the ASME Online Store at [www.asme.org](http://www.asme.org)***

*ASME A112.4.14-2017/CSA B125.14-17*  
***Manually operated valves for use in  
plumbing systems***



*®A trademark of the Canadian Standards Association, operating as "CSA Group"*

*Published in June 2017 by CSA Group  
A not-for-profit private sector organization  
178 Rexdale Boulevard, Toronto, Ontario, Canada M9W 1R3*

*To purchase standards and related publications, visit our Online Store at [shop.csa.ca](http://shop.csa.ca)  
or call toll-free 1-800-463-6727 or 416-747-4044.*

*ISBN 978-1-4883-0740-9*

*© 2017 CSA Group  
All rights reserved. No part of this publication may be reproduced in any form whatsoever  
without the prior permission of the publisher.*

## Commitment for Amendments

This Standard is issued jointly by the American Society of Mechanical Engineers (ASME) and the Canadian Standards Association (Operating as “CSA Group”). Amendments to this Standard will be made only after processing according to the Standards writing procedures of both ASME and CSA Group.

The American Society of Mechanical Engineers (ASME)  
Two Park Avenue  
New York, NY 10016-5990  
USA  
1-800-843-2763  
Visit the ASME Online Store at  
[www.asme.org](http://www.asme.org)

Copyright © 2017 by The American Society of Mechanical Engineers (ASME)

The 2017 edition of this Standard is being issued with an automatic addenda subscription service. The use of addenda allows revisions made in response to public review comments or committee actions to be published as necessary.

Published in June 2017 by  
CSA Group  
A not-for-profit private sector organization  
178 Rexdale Boulevard  
Toronto, Ontario, Canada  
M9W 1R3  
1-800-463-6727 or 416-747-4044  
Visit the CSA Group Online Store at  
[shop.csa.ca](http://shop.csa.ca)

ISBN 978-1-4883-0740-9

© CSA Group — 2017

All rights reserved. No part of this publication may be reproduced in any form whatsoever without the prior permission of the publisher.

# Contents

ASME A112 Standards Committee on Plumbing Materials and Equipment	3
ASME A112.4.14 Project Team on Quarter Turn Valves	6
CSA Technical Committee on Plumbing Fixtures	7
CSA/ASME Harmonization Task Group on Plumbing Fittings (B125-JHTG)	12
Preface	14
<b>1 Scope</b>	<b>16</b>
<b>2 Reference publications</b>	<b>17</b>
<b>3 Definitions and abbreviations</b>	<b>19</b>
3.1 Definitions	19
3.2 Abbreviations	19
<b>4 Design requirements</b>	<b>19</b>
4.1 Rated pressure and temperatures	19
4.2 End connections	19
4.2.1 Taper pipe threads	19
4.2.2 Solder joints	20
4.2.3 Solvent cement connections	20
4.2.4 PEX connections	20
4.2.5 Flared connections	20
4.2.6 Grooved ends	20
4.2.7 Push-fit fittings	20
4.2.8 Press-connect fittings	20
4.2.9 Other connections	20
4.3 Materials	20
4.3.1 General	20
4.3.2 Copper alloys	20
4.3.3 Ferrous alloys	20
4.3.4 Polymeric materials	20
4.3.5 Alternate materials	21
4.4 Toxicity and lead content	21
4.5 Stem design	21
<b>5 Performance requirements and test procedures</b>	<b>21</b>
5.1 Burst pressure	21
5.1.1 Performance requirements	21
5.1.2 Test procedure	21
5.1.3 Alternate test procedure	21
5.2 Hydrostatic test	22
5.2.1 Performance requirements	22
5.2.2 Test procedure	22

5.3	Static and dynamic seals	22
5.3.1	Performance requirements	22
5.3.2	Test procedure	22
5.4	Cycle test	22
5.4.1	Performance requirements	22
5.4.2	Test procedure	22
5.5	Flow test	22
5.5.1	Performance requirements	22
5.5.2	Test procedure	23
5.6	Operating requirements	23
5.6.1	Performance requirements	23
5.6.2	Test procedure	23
5.7	Resistance to installation loading	23
5.7.1	Performance requirements	23
5.7.2	Test procedure	23
<b>6</b>	<b>Markings</b>	<b>23</b>
6.1	General	23
6.2	Packaging	23

---

Annex A (informative)	— Unit conversion and rounding criteria	25
-----------------------	---	----

# ***ASME A112 Standards Committee on Plumbing Materials and Equipment***

<b>W.M. Smith</b>	American Society of Plumbing Engineers, Montgomery, Alabama, USA	<i>Chair</i>
<b>S. Rawalpindiwala</b>	Kohler Co., Kohler, Wisconsin, USA	<i>Vice-Chair</i>
<b>C. McLeod</b>	Kohler Co., Dana Point, California, USA	<i>Alternate</i>
<b>R.K. Adler</b>	City of San Jose, San Jose, California, USA	
<b>J.A. Ballanco</b>	JB Engineering & Code Consulting, PC, Munster, Indiana, USA	
<b>J.E. Bertrand</b>	Moen Incorporated, North Olmsted, Ohio, USA	
<b>A. Bonlender</b>	Bradley Corporation, Menomonee Falls, Wisconsin, USA	
<b>R. Burnham</b>	Zurn Industries LLC, Erie, Pennsylvania, USA	
<b>M. Campos</b>	ICC Evaluation Service, LLC, Brea, California, USA	
<b>S.L. Cavanaugh</b>	Cavanaugh Consulting, Santa Fe, New Mexico, USA	<i>Contributing Member</i>
<b>W.E. Chapin</b>	Professional Code Consulting, LLC, Cullman, Alabama, USA	
<b>P.V. DeMarco</b>	IAPMO, Dayton, New Jersey, USA	
<b>N.E. Dickey</b>	CSA Group, Cleveland, Ohio, USA	

<b>F. DiFolco</b>	CSA Group, Toronto, Ontario, Canada	<i>Alternate</i>
<b>G.S. Duren</b>	Code Compliance, Inc., S Pasadena, Florida, USA	
<b>R. Emmerson</b>	Consultant, Mundelein, Illinois, USA	
<b>C.L. Jahrling</b>	ASSE International, Chicago, Illinois, USA	<i>Contributing Member</i>
<b>R.L. George</b>	Plumb-Tech Design and Consulting Services L.L.C, Newport, Michigan, USA	
<b>G.W. Harrison</b>	Wayne Harrison Consulting, Edmond, Oklahoma, USA	
<b>L. Himmelblau</b>	Chicago Faucet, Des Plaines, Illinois, USA	
<b>J.M. Koeller</b>	Koeller and Co., Yorba Linda, California, USA	
<b>N. M. Kummerlen</b>	Consultant, Lorain, Ohio, USA	<i>Contributing Member</i>
<b>C.J. Lagan</b>	American Standards, Piscataway, New Jersey, USA	
<b>M. Malatesta</b>	American Standard, Piscataway, New Jersey, USA	<i>Alternate</i>
<b>J.W. Lauer</b>	Sloan Valve Company, Anaheim, California, USA	
<b>D. Gliberman</b>	Sloan Valve Company, Los Angeles, California, USA	<i>Alternate</i>
<b>W.H. LeVan</b>	Cast Iron Soil Pipe Institute, Fayetteville, Georgia, USA	
<b>D. Marbry</b>	Fluidmaster, Inc., San Juan Capistrano, California, USA	

<b>R. Mata</b>	CSA Group, Cleveland, Ohio, USA	
<b>D. Liang</b>	CSA Group, Guangzhou, China	<i>Alternate</i>
<b>L.A. Mercer</b>	IAPMO, Mokena, Illinois USA	
<b>D. Viola</b>	IAPMO, Mokena, Illinois USA	<i>Alternate</i>
<b>D. Orton</b>	NSF International, Ann Arbor, Michigan, USA	
<b>A. Ciechanowski</b>	NSF International, Ann Arbor, Michigan, USA	<i>Alternate</i>
<b>S.A. Remedios</b>	Remedios Consulting LLC, London, Ontario, Canada	
<b>M. Sigler</b>	Plumbing Manufacturers International, Orlando, Florida, USA	
<b>G.L. Simmons</b>	Charlotte Pipe & Foundry, Charlotte, North Carolina, USA	
<b>W.B. Morris</b>	Charlotte Pipe & Foundry, Charlotte, North Carolina, USA	<i>Alternate</i>
<b>J.C. Watson</b>	Elkay Manufacturing, Oak Brook, Illinois, USA	
<b>M. Weiss</b>	Plumbing and Drainage Institute, Polson, Montana, USA	
<b>W.C. Whitehead</b>	Whitehead Consulting Services, Peabody, Massachusetts, USA	
<b>A.L. Guzman Rodriguez</b>	American Society of Mechanical Engineers, New York, New York, USA	<i>Staff Secretary</i>

# ASME A112.4.14 Project Team on Quarter Turn Valves

<b>M. Campos</b>	ICC Evaluation Service, LLC, Brea, California, USA	<i>Chair</i>
<b>J.E. Bertrand</b>	Moen Incorporated, North Olmsted, Ohio, USA	
<b>W.E. Chapin</b>	Professional Code Consulting, LLC, Cullman, Alabama, USA	
<b>N.E. Dickey</b>	CSA Group, Cleveland, Ohio, USA	
<b>C. Erickson</b>	Underwriters' Laboratories, Northbrook, Illinois, USA	
<b>R.L. George</b>	Plumb-Tech Design and Consulting Services L.L.C., Newport, Michigan, USA	
<b>J.F. Higdon</b>	Apollo Valves/Conbraco Industries, Pageland, South Carolina, USA	
<b>D. Marbry</b>	Fluidmaster, Inc.,, San Juan Capistrano, California, USA	
<b>D. Orton</b>	NSF International, Ann Arbor, Michigan, USA	
<b>C. Osteen</b>	Reliance Worldwide Corp, Cullman, Alabama, USA	
<b>S.A. Remedios</b>	Remedios Consulting LLC, London, Ontario, USA	
<b>M. Sigler</b>	Plumbing Manufacturers International, Orlando, Florida, USA	

# CSA Technical Committee on Plumbing Fixtures

<b>S.M. Rawalpindiwala</b>	Kohler Co. Plumbing Division, Kohler, Wisconsin, USA <i>Category: Producer Interest</i>	<i>Chair</i>
<b>F. Lemieux</b>	Health Canada, Ottawa, Ontario, Canada <i>Category: Regulatory Authority</i>	<i>Vice-Chair</i>
<b>M. Al Hares</b>	Delta Faucet Company, Fishers, Indiana, USA	<i>Associate</i>
<b>W.T. Ball</b>	WCM Industries Inc., Colorado Springs, Colorado, USA	<i>Associate</i>
<b>J.E. Bertrand</b>	Moen Incorporated, North Olmsted, Ohio, USA <i>Category: Producer Interest</i>	
<b>A. Bonlender</b>	Bradley Corporation, Menomonee Falls, Wisconsin, USA	<i>Associate</i>
<b>T. Burke</b>	Victoria + Albert Baths Ltd., Telford, United Kingdom	<i>Associate</i>
<b>R. Burnham</b>	Zurn Industries LLC, Erie, Pennsylvania, USA <i>Category: Producer Interest</i>	
<b>M. Campos</b>	International Code Council, Brea, California, USA	<i>Associate</i>
<b>W.E. Chapin</b>	Professional Code Consulting, LLC, Cullman, Alabama, USA	<i>Associate</i>
<b>S. Chen</b>	Masco R&D, Taylor, Michigan, USA	<i>Associate</i>
<b>Y. Duchesne</b>	Régie du bâtiment du Québec, Québec, Québec, Canada <i>Category: Regulatory Authority</i>	

<b>C. Erickson</b>	Underwriters Laboratories Inc., Northbrook, Illinois, USA	<i>Associate</i>
<b>K. Ernst</b>	Oakville Stamping & Bending Limited, Oakville, Ontario, Canada <i>Category: Producer Interest</i>	
<b>W. Falcomer</b>	The Corporation of the City of Ottawa, Ottawa, Ontario, Canada <i>Category: Regulatory Authority</i>	
<b>F. Fernández</b>	Toto U.S.A. Inc., Ontario, California, USA <i>Category: Producer Interest</i>	
<b>M.E. Fish</b>	Zurn Industries, LLC, Cary, North Carolina, USA	<i>Associate</i>
<b>M.R. Gibeault</b>	Kohler Co. Plumbing Division, Kohler, Wisconsin, USA	<i>Associate</i>
<b>D. Gleiberman</b>	Sloan, Los Angeles, California, USA	<i>Associate</i>
<b>R. Guinn</b>	Oro-Medonte, Ontario, Canada <i>Category: User Interest</i>	
<b>R. Hildebrand</b>	The Regional Municipality of Waterloo, Kitchener, Ontario, Canada <i>Category: User Interest</i>	
<b>L. Himmelblau</b>	Chicago Faucets Geberit Manufacturing Division, Des Plaines, Illinois, USA <i>Category: Producer Interest</i>	
<b>E. Ho</b>	IAPMO Research & Testing Inc., Markham, Ontario, Canada	<i>Associate</i>
<b>E. Hood</b>	H. H. Angus & Associates Ltd., Toronto, Ontario, Canada <i>Category: User Interest</i>	
<b>K.S. Hui</b>	Ontario Ministry of Municipal Affairs, Toronto, Ontario, Canada <i>Category: Regulatory Authority</i>	

<b>C. Jahrling</b>	ASSE International, Mokena, Illinois, USA	<i>Associate</i>
<b>J. Knapton</b>	Southern Alberta Institute of Technology, Calgary, Alberta, Canada <i>Category: General Interest</i>	
<b>J.M. Koeller</b>	Koeller and Company, Yorba Linda, California, USA <i>Category: General Interest</i>	
<b>C.J. Lagan</b>	LIXEL Water Technologies Americas, Piscataway, New Jersey, USA <i>Category: Producer Interest</i>	
<b>D. Liang</b>	CSA Group, Guangzhou, China	<i>Associate</i>
<b>R. Liao</b>	Xiamen Lota International Co. Ltd., Xiamen, China	<i>Associate</i>
<b>J. MacDonald</b>	BLANCO Canada Inc., Brampton, Ontario, Canada	<i>Associate</i>
<b>J. Manente</b>	Region of Peel, Brampton, Ontario, Canada	<i>Associate</i>
<b>D. Marbry</b>	Fluidmaster Inc., San Juan Capistrano, California, USA	<i>Associate</i>
<b>T.J. McCann</b>	Department of National Defence, Ottawa, Ontario, Canada <i>Category: User Interest</i>	
<b>D. McNamara</b>	Franke Kindred Canada Limited, Midland, Ontario, Canada <i>Category: Producer Interest</i>	
<b>A.I. Murra</b>	Abraham Murra Consulting, Oakville, Ontario, Canada	<i>Associate</i>
<b>R. Neff</b>	Delta Faucet Company, Indianapolis, Indiana, USA	<i>Associate</i>

<b>D. Orton</b>	NSF International, Ann Arbor, Michigan, USA	<i>Associate</i>
<b>R. Pickering</b>	Eastern Research Group, Inc. (ERG), Morrisville, North Carolina, USA	<i>Associate</i>
<b>S.A. Remedios</b>	Remedios Consulting LLC, London, Ontario, Canada <i>Category: General Interest</i>	
<b>S. Shang</b>	China Building Material Test & Cert. Group (Shaanxi) Co. Ltd., Shaanxi, China	<i>Associate</i>
<b>R. Sharma</b>	U.S. Environmental Protection Agency, Washington, DC, USA	<i>Associate</i>
<b>M. Sigler</b>	Plumbing Manufacturers Int'l, Orlando, Florida, USA	<i>Associate</i>
<b>W. Smith</b>	American Society of Plumbing Engineers (ASPE), Montgomery, Alabama, USA <i>Category: General Interest</i>	
<b>J. St-Denis</b>	Intertek Testing Services NA Ltd. Services d'essais Intertek AN Ltee., Lachine, Québec, Canada	<i>Associate</i>
<b>D. Stoesz</b>	Alberta Municipal Affairs, Red Deer, Alberta, Canada <i>Category: Regulatory Authority</i>	
<b>S. Tanner</b>	U.S. Environmental Protection Agency, Washington, DC, USA <i>Category: General Interest</i>	
<b>P. Tardif</b>	National Research Council Canada, Canadian Codes Centre, Ottawa, Ontario, Canada	<i>Associate</i>
<b>C.W. Trendelman</b>	Bargersville, Indiana, USA	<i>Associate</i>
<b>J.C. Watson</b>	Elkay, Oak Brook, Illinois, USA	<i>Associate</i>

<b>C. Wright</b>	Ontario Pipe Trades, Dundalk, Ontario, Canada <i>Category: User Interest</i>	
<b>F. Zhang</b>	China Building Material Test & Cert. Group (Shaanxi) Co. Ltd., Shaanxi, China	<i>Associate</i>
<b>L. Pilla</b>	CSA Group, Toronto, Ontario, Canada	<i>Project Manager</i>

# ***CSA/ASME Harmonization Task Group on Plumbing Fittings (B125-JHTG)***

<b>C.J. Lagan</b>	LIXEL Water Technologies Americas, Piscataway, New Jersey, USA	<i>Co-Chair</i>
<b>F. Lemieux</b>	Health Canada, Ottawa, Ontario, Canada	<i>Co-Chair</i>
<b>M. Campos</b>	ICC Evaluation Service, LLC, Brea, California, USA	
<b>I. Chang</b>	Intertek Testing Services NA Ltd., Coquitlam, British Columbia, Canada	
<b>N.E. Dickey</b>	CSA Group, Cleveland, Ohio, USA	
<b>K. Ernst</b>	Oakville Stamping & Bending Limited, Oakville, Ontario, Canada	
<b>W. Falcomer</b>	The Corporation of the City of Ottawa, Ottawa, Ontario, Canada	
<b>F. Fernández</b>	Toto U.S.A. Inc., Ontario, California, USA	
<b>L. Himmelblau</b>	Chicago Faucets Geberit Manufacturing Division, Des Plaines, Illinois, USA	
<b>E. Ho</b>	IAPMO Research & Testing Inc., Markham, Ontario, Canada	
<b>N. M. Kummerlen</b>	Consultant, Lorain, Ohio, USA	
<b>B. Lagueux</b>	Saint-Nicolas, Québec, Canada	
<b>D. McNamara</b>	Franke Kindred Canada Limited, Midland, Ontario, Canada	

<b>S.M. Rawalpindiwala</b>	Kohler Co. Plumbing Division, Kohler, Wisconsin, USA	<i>Chair</i>
<b>S.A. Remedios</b>	Remedios Consulting LLC, London, Ontario, Canada	
<b>C. Wright</b>	Ontario Pipe Trades, Dundalk, Ontario, Canada	
<b>L. Pilla</b>	CSA Group, Toronto, Ontario, Canada	<i>Project Manager</i>

# Preface

This is the first edition of ASME A112.4.14/CSA B125.14, *Manually operated shutoff valves for use in plumbing systems*. This Standard replaces ASME A112.4.14-2004, *Manually operated, quarter-turn shutoff valves for use in plumbing systems*.

This Standard is considered suitable for use with conformity assessment within its stated scope.

This Standard was prepared by the ASME/CSA Harmonization Task Group on Plumbing Fixtures, under the jurisdiction of the ASME A112 Standards Committee on Plumbing Materials and Equipment and the CSA Technical Committee on Plumbing Fixtures. The CSA Technical Committee operates under the jurisdiction of the CSA Strategic Steering Committee on Construction and Civil Infrastructure. This Standard has been formally approved by the ASME Standards Committee and the CSA Technical Committee. This Standard was approved as an American National Standard by the American National Standards Institute on June 1, 2017.

## ASME Notes:

- 1) *This standard was developed under procedures accredited as meeting the criteria for American National Standards and it is an American National Standard. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed Standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.*
- 2) *ASME does not “approve,” “rate,” or “endorse” any item, construction, proprietary device, or activity.*
- 3) *ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.*
- 4) *Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this standard.*
- 5) *ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.*
- 6) *ASME issues written replies to inquiries concerning interpretation of technical aspects of this Standard. All inquiries regarding this Standard, including requests for interpretations, should be addressed to:*  
*Secretary, A112 Standards Committee*  
*The American Society of Mechanical Engineers*  
*Two Park Avenue*  
*New York, NY 10016-5990*

*A request for interpretation should be clear and unambiguous. The request should*

- *cite the applicable edition of the Standard for which the interpretation is being requested.*
- *phrase the question as a request for an interpretation of a specific requirement suitable for general understanding and use, not as a request for an approval of a proprietary design or situation. The inquirer may also include any plans or drawings, which are necessary to explain the question; however, they should not contain proprietary names or information.*

*ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME Committee.*

*Interpretations are published on the ASME Web site under the Committee Pages at <http://www.asme.org/codes/> as they are issued.*

#### **CSA Notes:**

- 1) *Use of the singular does not exclude the plural (and vice versa) when the sense allows.*
- 2) *Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.*
- 3) *This Standard was developed by consensus, which is defined by CSA Policy governing standardization — Code of good practice for standardization as “substantial agreement. Consensus implies much more than a simple majority, but not necessarily unanimity”. It is consistent with this definition that a member may be included in the Technical Committee list and yet not be in full agreement with all clauses of this Standard.*
- 4) *To submit a request for interpretation of this Standard, please send the following information to [inquiries@csagroup.org](mailto:inquiries@csagroup.org) and include “Request for interpretation” in the subject line:*
  - a) *define the problem, making reference to the specific clause, and, where appropriate, include an illustrative sketch;*
  - b) *provide an explanation of circumstances surrounding the actual field condition; and*
  - c) *where possible, phrase the request in such a way that a specific “yes” or “no” answer will address the issue.*

*Committee interpretations are processed in accordance with the CSA Directives and guidelines governing standardization and are available on the Current Standards Activities page at [standardsactivities.csa.ca](http://standardsactivities.csa.ca).*
- 5) *This Standard is subject to review five years from the date of publication. Suggestions for its improvement will be referred to the appropriate committee. To submit a proposal for change, please send the following information to [inquiries@csagroup.org](mailto:inquiries@csagroup.org) and include “Proposal for change” in the subject line:*
  - a) *Standard designation (number);*
  - b) *relevant clause, table, and/or figure number;*
  - c) *wording of the proposed change; and*
  - d) *rationale for the change.*

# ***ASME A112.4.14-2017/CSA B125.14-17 Manually operated valves for use in plumbing systems***

## **1 Scope**

### **1.1**

This Standard specifies requirements for manually operated valves, also known as supply line stops, in sizes NPS 4 and smaller.

### **1.2**

Valves covered by this Standard are intended for

- a) installation as water shutoff valves between the meter and the supply stop; and
- b) service at temperatures between 5 °C (40 °F) and 71 °C (160 °F), with an allowable working pressure rating not less than 862 kPa (125 psi).

### **1.3**

This Standard does not apply to hose end valves or endpoint devices as defined in Section 9 of NSF/ANSI 61.

### **1.4**

In this Standard, “shall” is used to express a requirement, i.e., a provision that the user is obliged to satisfy in order to comply with the standard; “should” is used to express a recommendation or that which is advised but not required; and “may” is used to express an option or that which is permissible within the limits of the Standard.

Notes accompanying clauses do not include requirements or alternative requirements; the purpose of a note accompanying a clause is to separate from the text explanatory or informative material.

Notes to tables and figures are considered part of the table or figure and may be written as requirements.

Annexes are designated normative (mandatory) or informative (non-mandatory) to define their application.

### **1.5**

SI units are the units of record in Canada. In this Standard, the yard/pound units are shown in parentheses.

The values stated in each measurement system are equivalent in application; however, each system is to be used independently. Combining values from the two measurement systems can result in non-conformance with this Standard.

All references to gallons are to U.S. gallons.

For information on the conversion criteria used in this Standard, see Annex [A](#).

## 2 Reference publications

This Standard refers to the following publications, and where such reference is made, it shall be to the edition listed below, including all amendments published thereto.

### **ASME (The American Society of Mechanical Engineers)/CSA Group**

ASME A112.18.1-2012/CSA B125.1-2012

*Plumbing supply fittings*

### **ASME (The American Society of Mechanical Engineers)**

B1.1-2003 (R2008)

*Unified Inch Screw Threads, (UN and UNR Thread Form)*

B1.20.1-2013

*Pipe Threads, General Purpose, Inch*

B16.18-2012

*Cast Copper Alloy Solder Joint Pressure Fittings*

B16.22-2013

*Wrought Copper and Copper Alloy Solder Joint Pressure Fittings*

B16.26-2013

*Cast Copper Alloy Fittings for Flared Copper Tubes*

B16.51-2013

*Copper and Copper Alloy Press-Connect Pressure Fittings*

### **CSA Group**

B242-05 (R2016)

*Groove-and shoulder-type mechanical pipe couplings*

CSA B137.5-17

*Crosslinked polyethylene (PEX) tubing systems for pressure applications*

CSA B137.6-17

*Chlorinated polyvinylchloride (CPVC) pipe, tubing, and fittings for hot- and cold-water distribution systems*

### **ASSE (American Society of Sanitary Engineering)**

1061-2015

*Performance Requirements for Push-Fit Fittings*

### **ASTM International (American Society for Testing and Materials)**

D1599-2014e1

*Standard Test Method for Resistance to Short-Time Hydraulic Pressure of Plastic Pipe, Tubing, and Fittings*

D1784-2011

*Standard with Specification for Rigid Poly (Vinyl Chloride) (PVC) Compounds and Chlorinated Poly (Vinyl Chlorinated) (CPVC) Compounds*

D2466-2015

*Standard Specification for Poly (Vinyl Chloride) (PVC) Plastic Pipe Fittings, Schedule 40*

D2467-2015

*Standard Specification for Poly (Vinyl Chloride) (PVC) Plastic Pipe Fittings, Schedule 80*

D2846-2014

*Standard Specification for Chlorinated Poly (Vinyl Chloride) (CPVC) Plastic Hot- and Cold- Water Distribution Systems*

E29-2013

*Standard Practice for Using Significant Digits in Test Data to Determine Conformance with Specifications*

F439-2013

*Standard Specification for Chlorinated Poly (Vinyl Chloride) (CPVC) Plastic Pipe Fittings, Schedule 80*

F1498-2008(2012)e1

*Standard Specification for Metallic Mechanical Fittings for Use on Outside Diameter Controlled Thermoplastic Gas Distribution Pipe and Tubing*

F1970-2012e1

*Standard Specification for Special Engineered Fittings, Appurtenances or Valves for use in Poly (Vinyl Chloride) (PVC) and Chlorinated Poly (Vinyl Chlorinated) (CPVC) Systems*

#### **AWWA (American Water Works Association)**

C606-2015

*Grooved and Shouldered Joints*

#### **NSF International**

NSF/ANSI 61-2016

*Drinking Water System Components — Health Effects*

NSF/ANSI 359-2016

*Valves for Crosslinked Polyethylene (PEX) Water Distribution Tubing Systems*

NSF/ANSI 372-2016

*Drinking Water System Components — Lead content*

#### **ISA (The International Society of Automation)**

ISA/ANSI 75.01.01-2012 (IEC 60534-2-1 MOD)

*Industrial-Process Control Valves — Part 2-1: Flow capacity — Sizing equations for fluid flow under installed conditions*

## 3 Definitions and abbreviations

### 3.1 Definitions

The following definitions shall apply in this Standard:

**Fine control valve** — a valve designed to accurately and precisely adjust the flow of water (e.g., needle valve).

**Flow coefficient ( $C_v$ )** — flow coefficient is a relative measure of a valve's efficiency at allowing fluid flow. Numerically  $C_v$  is equal to the number of gallons of water at 60 °F that will flow through the valve in 1 minute when the pressure differential across the valve is 1 psi.

**Note:** See definition of **Flow factor**.

**Flow factor ( $K_v$ )** — the flow rate, measured in cubic meters per hour, of water at 16 °C with a pressure drop across the valve of 100kPa.

**Note:** The flow factor is the metric equivalent to the flow coefficient ( $C_v$ ) and it is used in Europe and Asia

**Supply line stop** — a valve used to control the flow of water in a distribution system, except a supply stop.

**Supply stop** — a valve that is placed immediately upstream of a terminal fitting to shut off the water supply to the terminal fitting so that it can be serviced or replaced.

**Valve** — a fitting with a movable part that regulates the flow of water through one or more passages.

### 3.2 Abbreviations

The following abbreviations shall apply in this Standard:

CPVC = chlorinated polyvinylchloride

$C_v$  = flow coefficient

$K_v$  = flow factor

NPS = nominal pipe size

PEX = crosslinked polyethylene

PVC = polyvinylchloride

## 4 Design requirements

### 4.1 Rated pressure and temperatures

Valves shall be designed for temperatures between 5 °C (40 °F) and 71 °C (160 °F), with an allowable working pressure rating not less than 862 kPa (125 psi).

### 4.2 End connections

#### 4.2.1 Taper pipe threads

Metallic taper pipe threads shall be in accordance with ASME B1.20.1. Plastic taper pipe threads shall be in accordance with ASTM F1498.

### 4.2.2 Solder joints

The dimensions of solder joint ends for connection to copper tubes or fittings (other than factory-assembled parts) shall comply with ASME B16.18 or ASME B16.22, as applicable.

### 4.2.3 Solvent cement connections

Socket ends for solvent-cement connection to PVC or CPVC pipe or tube shall be in accordance with

- a) ASTM D2466 or ASTM D2467 for connections to PVC pipe; and
- b) ASTM D2846, ASTM F439 or CSA B137.6 for connections to CPVC pipe.

### 4.2.4 PEX connections

Valves for connection to PEX water distribution systems tubing shall be in accordance with the applicable requirements in Clause 5 of NSF/ANSI 359 or Clause 5 of CSA B137.5.

### 4.2.5 Flared connections

Flared connections to copper tube shall be in accordance with ASME B16.26. The screw thread dimensions of flared and ball sleeve (compression) tube fittings shall comply with ASME B1.1.

### 4.2.6 Grooved ends

Grooved end connections shall be in accordance with AWWA C606 or CSA B242.

### 4.2.7 Push-fit fittings

Connections achieved by push-fit fittings shall comply with ASSE 1061.

### 4.2.8 Press-connect fittings

Ends of press-connect fittings shall be in accordance with ASME B16.51.

### 4.2.9 Other connections

Connection methods not specified herein shall be in accordance with a nationally or internationally recognized standard.

## 4.3 Materials

### 4.3.1 General

The requirements in Clauses 4.3.2 to 4.3.5 pertain to materials used in valve body, bonnet, end pieces, pressure-containing parts, and wetted operating parts.

### 4.3.2 Copper alloys

Copper alloys shall have a copper content of at least 58% by weight.

### 4.3.3 Ferrous alloys

Ferrous alloys shall be stainless steel 300 or 400 series.

### 4.3.4 Polymeric materials

#### 4.3.4.1

PEX compounds shall be suitable for use within the rated temperature range.

#### 4.3.4.2

PVC compounds used for pressure containing parts shall comply with cell classification 12454, 13354, 11443, or 14333, as specified in ASTM D1784.

#### 4.3.4.3

CPVC compounds used for pressure containing parts shall comply with cell classification 23447, as specified in ASTM D1784.

#### 4.3.5 Alternate materials

Alternate materials shall comply with national or international standards for which mechanical and chemical data are available.

### 4.4 Toxicity and lead content

#### 4.4.1

Valves intended for potable use shall comply with the applicable requirements of NSF/ANSI 61.

#### 4.4.2

Solders and fluxes in contact with potable water shall not exceed, by mass, 0.2% lead content. Metal alloys in contact with potable water shall not exceed 8% lead content.

#### 4.4.3

Valves intended to convey or dispense water for human consumption through drinking or cooking shall not contain a weighted average lead content in excess of 0.25% when evaluated in accordance with the test method in NSF/ANSI 372.

### 4.5 Stem design

The valve shall be designed so that the stem-seal alone does not retain the stem to prevent the removal of the stem while the valve is under pressure.

## 5 Performance requirements and test procedures

### 5.1 Burst pressure

#### 5.1.1 Performance requirements

When tested in accordance with Clause 5.1.2 or 5.1.3, the valve shall show no signs of leakage, permanent distortion, or failure of the pressure envelope.

#### 5.1.2 Test procedure

The test specimen shall withstand a hydrostatic burst pressure of 3450 kPa (500 psi) at a temperature of  $23 \pm 2$  °C ( $73 \pm 4$  °F) for 1 min. The pressure shall be applied to the inlet with the outlet blocked and the valve open.

#### 5.1.3 Alternate test procedure

Valves rated in excess of 71 °C (160 °F) and 862 kPa (125 psi) shall be tested in accordance with ASTM D1599 at a temperature of  $23$  °C  $\pm$   $2$  °C ( $73$  °F  $\pm$   $4$  °F). The burst pressure shall not be less than three

times the manufacturer's maximum rated pressure at that temperature. A second test specimen shall be tested in accordance with ASTM D1599 at a temperature of  $82\text{ °C} \pm 2.0\text{ °C}$  ( $180.0\text{ °F} \pm 4\text{ °F}$ ) or the manufacturer's maximum rated temperature, whichever is greater. The burst pressure for the second valve shall not be less than two times the manufacturer's rated pressure at the test temperature.

## 5.2 Hydrostatic test

### 5.2.1 Performance requirements

When tested in accordance with Clause 5.2.2, the valve exterior shall show no visible leakage. Leakage through the stem packing shall not be cause for rejection as long as a packing gland adjustment stops the leakage.

### 5.2.2 Test procedure

The hydrostatic test shall be conducted as follows:

- a) Metallic valves shall be tested at two times its marked pressure rating for 1 min. The test fluid shall be water and its temperature shall be  $60 \pm 2.0\text{ °C}$  ( $140 \pm 4\text{ °F}$ ). The valve shall be in the open position during the test to ensure full pressurization of the valve.
- b) Polymeric valves shall be tested in accordance with Section 8.2 of ASTM F1970.

## 5.3 Static and dynamic seals

### 5.3.1 Performance requirements

When tested in accordance with Clause 5.3.2, the valve seals shall not leak or otherwise fail.

### 5.3.2 Test procedure

The valve seals shall be tested in accordance with the applicable requirements in Clauses 5.3.1.2 to 5.3.1.4 of ASME A112.18.1/CSA B125.1.

## 5.4 Cycle test

### 5.4.1 Performance requirements

When tested in accordance with Clause 5.4.2, the valves shall continue to function as they did before the life cycle and shall not leak.

### 5.4.2 Test procedure

A test specimen shall withstand 2,000 cycles of operation from the fully-opened to the fully-closed position at its maximum rated temperature not less than  $65 \pm 5\text{ °C}$  ( $150 \pm 10\text{ °F}$ ). Water at a flowing pressure of  $345 \pm 35\text{ kPa}$  ( $50 \pm 5\text{ psi}$ ) and a supply pressure of  $550\text{ kPa}$  ( $80\text{ psi}$ ) maximum (valve closed) shall be supplied to the valve throughout the test. An opening downstream of the valve shall be restricted to a flow of approximately  $9.5\text{ L/min}$  ( $2.5\text{ gpm}$ ) during the open portion of the test.

## 5.5 Flow test

### 5.5.1 Performance requirements

The valves shall meet the minimum flow rates specified in Table 1 or shall have a flow factor ( $K_v$ ) [flow coefficient ( $C_v$ )] factor equal to or greater than the values specified in Table 1.

Valves that are designed to also serve as a fine flow control devices may have flow rates (or  $K_v$  ( $C_v$ )) lower than those specified in Table 1, provided that the packaging specifies the rated flow rate at 140 kPa (20 psi) or  $K_v$  ( $C_v$ ) for the product.

### 5.5.2 Test procedure

The valves shall be tested in accordance with the applicable requirements of Clause 5.4 of ASME A112.18.1/CSA B125.1 or the  $K_v$  ( $C_v$ ) factor shall be determined in accordance with ISA/ANSI 75.01.01.

## 5.6 Operating requirements

### 5.6.1 Performance requirements

When closed, valves shall not leak when tested for 5 min in accordance with Clause 5.6.2.

### 5.6.2 Test procedure

For manually operated valves or operating controls, except for accessible designs, the torque or force required to open, operate, and close a manually activated valve or operating control shall not exceed the applicable operating torque or linear force specified in Table 2 when tested at temperatures and pressures specified in Clause 5.3.1.4 of ASME A112.18.1/CSA B125.1.

## 5.7 Resistance to installation loading

### 5.7.1 Performance requirements

Connections intended to seal water shall not crack, strip, or leak in accordance with Clause 5.7.2.

### 5.7.2 Test procedure

Valves shall be tested in accordance with Clause 5.7.2 of ASME A112.18.1/CSA B125.1.

## 6 Markings

### 6.1 General

#### 6.1.1

Valves covered by and complying with this Standard shall be marked with

- a) the manufacturer's name or trademark, or private labeler's name or trademark;
- b) the maximum working pressure-temperature for which the valve is designed;
- c) the size of the valve; and
- d) for unidirectional valves, the direction of flow.

#### 6.1.2

The marking shall be accomplished by use of a permanent mark or by placing a permanent label on the valve.

### 6.2 Packaging

Packaging shall be marked with

- a) the model number;

- b) the rated flow rate in L/min (gpm) at 140 kPa (20 psi) or Kv (Cv) value, for fine flow control devices only; and
- c) the manufacturer's recognized name, trademark, or other mark; or
- d) in the case of private labelling, the name, trademark or other mark of the customer for whom the valve was manufactured, as well as the model number.

**Table 1**  
**Minimum flow rates**  
(See Clause 5.5.)

NPS	Min flow, L/min (gpm)	K <sub>v</sub> (C <sub>v</sub> )
3/8	20 (5.3)	5 (6)
1/2	36 (10)	9 (10)
3/4	68 (18)	15 (17)
1	118 (30)	23 (27)
1-1/4	200 (50)	39 (45)
1-1/2	325 (85)	56 (65)
2	550 (145)	87 (100)
2-1/2	850 (225)	123 (142)
3	1150 (300)	151 (172)
3-1/2	1500 (400)	190 (220)
4	1900 (500)	225 (260)

**Note:** For determining compliance with this Table, observed or calculated values should be rounded to the nearest unit in accordance with ASTM E29.

**Table 2**  
**Operating requirements**  
(See Clause 5.6.)

Valve	Linear force, N (lbf)	Operating torque, N•m (lbf•in)
NPS-1/2 or smaller	67 (15)	1.7 (15)
Larger than NPS-1/2	110 (25)	2.8 (25)

**Note:** The specified torques and forces apply to the opening operation of the valves.

## *Annex A (informative)*

# **Unit conversion and rounding criteria**

**Note:** *This Annex is not a mandatory part of this Standard.*

### **A.1**

The following conversion rules are used in this Standard:

- a) Zeros to the left of the first non-zero digit are not significant.
- b) If the number is greater than 1, all zeros to the right of the decimal point are significant.
- c) In multiplication and division, the original number with the smallest number of significant digits determines the number of significant digits in the product or quotient.
- d) If an exact constant is used (e.g., 3 ft = 1 yd), it does not affect the number of significant digits in the calculated value.
- e) If inexact constants are used (e.g.,  $\pi = 3.1416$ ), the constant with at least one more significant digit than the smallest number of significant digits in the original data is used.

### **A.2**

The following rounding rules are used in this Standard:

- a) The digits that follow the last significant digit are dropped if the first digit is less than 5.
- b) If the first digit dropped is greater than 5, the preceding digit is increased by 1.
- c) If the first digit dropped is 5 and there are non-zero digits following the 5, the preceding digit is increased by 1.
- d) If the first digit dropped is 5 and there are only zeros following the 5, the digit is rounded to the even number (e.g., for three significant digits, 1.655000 becomes 1.66, 1.625000 becomes 1.62).
- e) For maximums and minimums, rounding is performed within the range of the maximum and minimum values in a way that does not violate the original limits.



**CSA  
Group**

ISBN 978-0-7918-7180-5



9 780791 871805



J 1 6 9 1 Q